



REVISIONS			
LTR	DESCRIPTION	DATE	APPROVAL
0	new		



TRIPLE CLEAR 3-STAGE POINT OF ENTRY FILTRATION SYSTEM		
EQUIPMENT LIST		
-	DESCRIPTION	MODEL NUMBER
1	(2) TECHCLEAN 10 MICRON FILTERS	ABW-6XLP (2)
2	(2) CARBON FILTERS	CVRW-60L-4F-B-20 (2)
3	TRIPLE CLEAR FORCEFIELD FILTER	STC-12-4F-35-304



400 GPM SYSTEM AT 150 PSI



Engineering Contact:
Michael Balboni
Direct: (713) 253-2320
Email: mbalboni@cougarusa.com

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN IS THE EXCLUSIVE PROPERTY OF COUGAR SALES, INC. AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION. THIS DOCUMENT IS ISSUED SOLELY AS A REFERENCE FILE. THIS DOCUMENT SHALL NOT BE USED FOR PERMITTING, BIDDING, OR CONSTRUCTION PURPOSES.

THIS REPRODUCTION IS A PROPRIETARY DESIGN AND CONFIDENTIAL INFORMATION OF UF STRAINRITE INC. AND IS LOANED SUBJECT TO THE CONDITIONS THAT: (1) IT SHALL BE USED OR CAUSED TO BE USED FOR RECORD AND REFERENCE PURPOSES; (2) IT SHALL NOT BE USED OR CAUSED TO BE USED FOR PROCUREMENT IN ANY WAY PREJUDICIAL TO UF STRAINRITE INC. INTERESTS; (3) IT SHALL NOT BE REPRODUCED OR COPIED IN WHOLE OR IN PART; AND (4) IT SHALL NOT BE DISCLOSED AS GENERAL OR SPECIFIC INFORMATION WITHOUT EXPRESSED CONSENT IN WRITING SIGNED BY AN AUTHORIZED REPRESENTATIVE OF UF STRAINRITE INC.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES ARE AS FOLLOW:
FRACTION $\pm 1/8$ ANGLES $\pm 1^\circ$
XX = $\pm .020$ XXX = $\pm .005$
MATERIAL: 304SS

ABW6-60L-STC12	
DRAWN BY: DCB	TRIPLE CLEAR
DATE: 4-22-20	
APPROVAL:	DWG #: TBD
SCALE: XX	
REV: 0	SHT. 1 OF 1
C	